Turkish Online Journal of Qualitative Inquiry (TOJQI) Volume 12, Issue 7, July 2021: 11851-11859

Examination and Determination of Partial Discharge Source using Gaussian Naive Bayes (GNB) Technique

Kajol Chaudhari^a, Akhilesh Kumar Mishra^b, Priyanka Kothoke^c, Yogesh Chaudhari^d

 ^aResearch Scholar, Shri J. J. T. University, Rajasthan, India,
 ^bProfessor, Shri J. J. T. University, Rajasthan, India,
 ^cAssistant Professor, MGM College of Engineering and Technology, Maharashtra, India
 ^dAssistant Professor, School of Engineering and Technology, Navrachana University, Vadodara, India
 ^akajolchaudhari20@gmail.com, ^c priyankakothoke250390@gmail.com

Abstract

The outline of partial discharge (PD) is an substantial instrument for high-voltage insulation systems diagnostics. In different PD data representations, human experts can detect possible isolation defects. PD (PRPD) patterns are one of the most commonly used representations. To ensure the confident operation of HV-equipment, the statistical properties of PDs must be linked to the defect properties and the type of defect determined. Classifier Naive Bayes are a family of simple 'probabilistic classifiers,' which use Bayes theorem with robust presumptions of independence among features. At the moment the GNB's importance in assessing its appropriateness for PD actions is being considered. The model is built in Google's Python co-laboratory and can be generated from the PD source on a graphical user interface, whether it is void, surface or crown discharge, using statistically based parameters. The model is also available for this method.

Keywords: Gaussian Naive Bayes, Google co-laboratory, Partial Discharge, Phase-Resolved.

Introduction

PD is a confined electrical discharge which bonds part of the insulation among electrodes and can occur head-to-head to a conductor or otherwise [1]. PDs usually concern dielectric materials used and bridge the voltage between the electrodes[2] in some respects. Strong, liquid or gaseous materials or any mixture of them may consist of the insulation. The PD is the main reason for high-voltage electrical equipment electrical aging and insulation. Different PD sources affect the isolation performance differently. In the assessment of the destructiveness of the discharge [2], PD classification is therefore important.

The PD classification is intended to identify unknown source discharges. For many years, the process has been carried out by examining the pattern of the flux on an oscilloscope screen using a well-known ellipse, which was crudely observed by the eye. Currently, extensive research has been published in order to recognize PD sources through smart technology, such as artificial neural networks, fluorescent logic and acoustic emissions [2].

In this part a new, fast-track digital and computer-based techniques and algorithm for the processing and analysis of PD-based measurement signals have driven the recent rise in the research on DP phenomena. With sufficiently advanced digital technology, it seems to be anticipated that no only new insights into the physical and chemical foundation of PD phenomena can be gained, but also that pd's patterns can be used to identify featments of the 'deficiencies' in the insulation of the observable PD [3]. A computer-aided measuring system's having a ability to process a large amount of information and convert it into a comprehensible output is an undeniable advantage [4]. Many kinds of patterns can be used to identify the defect type from the observable PD

pattern. Since each defect has its own special breakdown mechanism, the link between the release patterns and the type of defect is important to know [5]. As a result, progress in quality control in insulating systems is becoming increasingly important in recognizing internal discharge and its correlation with this type of defect [6]. The study of fractional discharge sources was carried out using statical numerical and neural network techniques [7]. During the experiments, there are three distinct classifications of PD pulse data patterns from digital PD detectors: phase data, time-resolved data, and data that lacks information on either phase or time.

- 1. Three-dimensional discharge epochs, f charge allocation, q discharge rate, n patterns ($\alpha \sim q$, $\sim n$ and $\sim n$ patterns), at a specific test voltage, are the data that are phase-resolved.
- 2. The time-solved data constitutes a certain time interval, i.e. q~t data pattern, for the individual release pulse magnitudes.
- **3.** The third information classification includes changes in pulse discharge amplitude to V-test voltage amplitude (for increasing and decreasing levels), i.e. q ~V data, respectively.

Out of these three classifications, phase resolved data method is used in this work for statistical method whose pre-processed data is used as an input to this GNB Technique. Phase resolved data is used since it is drawing 2D patterns from raw data showing variations between either phase angle and charge, phase angle and number of pulses or number of pulses and charge and then comparison of these patterns amongst themselves will result in improved accuracy of the outputs.

At present, in any industry, just the source of PD is notified by using a buzzer. However, the buzzer indicates only the place of its occurrence and not the type of discharge, which is very essential for removal of insulation defects. The technique suggested in this research enable to know the type of the PD accurately so that the insulation defects can be removed from any high voltage equipment by specific techniques to avoid chances of supply failure.

PDs should be marked with the phase angle", PD charge magnitude q and PD pulse numbers n being the key parameters. These three parameters consist of PD distribution patterns. For phase-resolved (f-q), (p-n), and statistic parameters are obtained (n-q).

PDs are characterized by phase angle \cdot , magnitude q of PD load, and by PD n. With respect to the 50 (± 5) Hz sine wave, pulse pulses are grouped by their phase angle. The voltage cycle is therefore divided into phase windows that represent the phase angle axis (0 to 360'). If observations for multiple voltage cycles are made, in each phase window a statistical distribution of individual PD events can be determined. Throughout this phase angle axis, the average values of these statistical distributions lead to two dimensional patterns for the observed PD patterns [8]. A 2-dimension (2-D) α -q and Ś-n distribution represents 'Q' and 'n' pulses as a function of the angle of phase, as the phase angle '5-0' PD charge magnitude [9]. The medium pulse allocation Hqn (ć) is the average magnitude of the PD charge in every window, depending on the angle of phase \pm . The distribution of the pulse counts Hn (ć) is the number of PD pulses within the window depending on the angle of phase \pm . Both of these quantities are further split into 2 separate negative and positive half cycle distributions, resulting in the emergence of 4 different distributions: positive half of the Hqn+ (5-0) and Hn+ (-) voltage cycles, negative half of the Hqn-(-2) and Hn-(-3) voltage cycles[9]. The normal distribution can be described as PD quantities for a single defect. Hqn's (ć) and Hn's (\pm) distribution profiles were modeled by the time of normal distribution: skewness and kurtosis. Pulse umber n. These three parameters consist of PD distribution patterns. For phase-resolved (f-q), (p-n), and statistic parameters are obtained (n-q).

The skewness and curtos is of the reference normal distribution are evaluated. Asymmetry or tilt degree of the data is a measure of skewness in terms of normal distribution. Sk=0 is a symmetrical distribution; left is asymmetric, Sk>0; right, Sk<0 is asymmetrical. Kurtosis represents an indicator of distribution sharpness. If the sharpness of the distribution is equal to the normal distribution, Ku=0. Sharing Ku>0, and Flatter Ku<0[10], if more sharp than normal.



Fig.1. A Systematic Flow of discharge analysis for (n-q)[15-17]

Where,

S.D = standard deviation

Sk = skewness

Ku = kurtosis

For the calculation of several statistical operators, statistical analysis is applied. The following definitions are described for most of such statistical operators. You can use a general function, i.e. yi=f(xi)[25-3], as a profile of all these discrete distribution functions. It is possible to calculate the statistical function:

The skewness and curtosis of the reference normal distribution are evaluated. Asymmetry or tilt degree of the data is a measure of skewness in terms of normal distribution. Sk=0 is a symmetrical distribution; left is asymmetric, Sk>0; right, Sk<0 is asymmetrical. Kurtosis represents an indicator of distribution sharpness. If the sharpness of the distribution is equal to the normal distribution, Ku=0. Ku>0 is sharper than normal and Ku<0 [11] [20] is flatter.

In our study, internal and external discharges of various kinds such as the void, the surface and the crown were tested using statistical parameters such as average, standard deviation, variance, skeshedness and kurtosis for (n-q), as explained above in fig. 1. After entering the five data values of statistical parameters as an input in Google's collaboratory in Python, GUI displays the type of discharge as input.

GAUSSIAN NAIVE BAYES CLASSIFIER

The classifying group based on Bayes Theorem is called Naive Bayes Classifiers, also referred to as simple Bayes and Bayes for independence. The common classification principle shares all classifiers in this category. The reason it was referred to as Naive Bayes is its assumption that there is no correlation between all attributes of a dataset and each attribute is independent. Classifiers from Naive Bayes could be easily scaled. The number of functions in a classification problem requires linear parameters. Naive Bayes training could be carried out with maximum similarity. Training in this kind of classifiers is fast because in classifiers in Naïve Bayes iterative approximation is not done. Naive Bayes is an easy classification technique. It models a classifier that gives instances of the test datasets a class label. The class label is drawn from the training set by each instance to be a vector of the feature values. There is no unique algorithm, but a common principal family of algorithms, to train such classification systems. All classifications in Naïve Bayes assume that the value of a specific characteristic is independent of the value of any other feature's class variable.

For some types of probability models, the Naive Bayes classifier can be very effectively trained in a supervised learning environment. Parameter approximation for models of Naive Bayes practices the highest probability technique in many practical ss. Revised Manuscript from Naive Bayes Posted on 22 December 2018. Shikha Agarwal, Computing Science Department, South Bihar Central University, Gaya, India. Balmukund Jha, Computer Science Department, South Bihar Central University, Gaya, India. Balmukund Jha, Computer Science Department of Computer Science. South Bihar Central University, Gaya, Indeed, Department of Computer Science, Manish Kumar. South Bihar, Gaya, Indian Central University, Prabhat Ranjan, Computer Science Department. Model can be used without acceptance or using Bayesian methods. Naive Bayes classification systems have worked quite well in a number of compound situations despite their naïve project and simple assumptions. The analysis of the Bayesian problem of classification showed that behind the apparently unbelievable efficiency of classifier types there are sound theoretical reasons. In 2006 an extensively comparing classification algorithms showed that the classification of bays was outperformed by

Kajol Chaudhari, Akhilesh Kumar Mishra, Priyanka Kothoke, Yogesh Chaudhari

other forests, such as boosted trees and random forests. The advantage and application of Naive Bayes is to approximation the parameters necessary for classification only by using a small number of training data. Naive Bayes works with a discrete value, which is the fundamental property. It is recommended to use the Gaussian Naive Bayes classifier [12] if attribute values are continuous.

Naive Bayes is a group of supervised techniques used for classification machines. Bayes Theorem is the core of this method of classification. For each class in the dataset, it predicts membership probabilities such as the probability that a data point is in a specific class. The most likely class of data points is the class with the highest probability of membership. On the basis of a training data set [13], Classifier identifies which category is a new observation.

Gaussian Naïve Bayes: GNB is a controlled algorithm that is used widely for classification problems due to its simplicity and precision. The Bayes framework is used and the independence between the independent variables is strongly supposed. One important advantage of GNB is the parameters required for small training sets to be classified [14].

Methodology

- Google colab is used for this study as open-source software is cheaper and easier to reach and can be adapted for future purposes. Five required parameters viz. mean, standard deviation, variance, skewness and kurtosis for both known (void, surface and corona) and unknown discharges (data1,data2 and data3) are given as an input for GNB method (as shown in Fig.2)
- 2. Initially, in Google Co- laboratory, common model is built. For model building, the obtained statistical required parameters are used for both training and testing.
- 3. Secondly and important the final processed file (merging all six known and unknown data) is created.
- 4. Thirdly, this built model of google colab is taken in python server for creating Graphical User Interface (GUI). GUI will display the type of discharge by entering the statistical parameters viz mean, standard deviation, variance, skewness and kurtosis[18][19].



Fig.2. Flow of techniques used

EXPERIMENTAL RESULTS

The output (type of discharge) for the above method viz GNB method will be shown by entering the input values (statistical parameters) as shown in figures below. Fig 3. below is showing the screenshot of window which will be used for entering input values and Fig 4. is used to select the method and Fig 5. shows the output.

PARTIAL DESCHARGE		
O Prediction	line	
③ Deahbeard	0.537367	
Data Analysis	Standard Deviation	
A Compare Madels	0.032369	
Group Prediction	Shewress	
	0.86588	
	Kurtosis 2 879909	
	No.	
	0.00046	
	Populane	Cuar

Fig.3. Figure showing the entered input values on GUI

n ways country						
Group Prediction	Ske	Wheel				
	0.8	11688				
	Let					
	100					
	2.87	79909				
	Var	6464				
	0.0	0048				
				Populate		
			Marial			
	Sr.no	Cetegory	None	Paraneters/Hyperparaneters		Action
	1	Traditional ML Model	6NB	GaussiandB(priors-Nove, var_smoothing-le-49)		Select
	_		_			_

Fig.4. Figure showing the icon to select the GNB Technique on GUI





Detailed clas	ssification	report:			
	precision	recall	f1-score	support	
0	0.81	0.73	0.77	907	
1	0.75	0.84	0.79	908	
2	0.97	0.95	0.96	863	
accuracy			0.84	2678	
macro avg	0.84	0.84	0.84	2678	
weighted avg	0.84	0.84	0.84	2678	

Fig.6. Figure showing the detailed classification report i.e. precision, recall, f1-score and support of GNB Technique

In Fig.6, "0" stands for known discharge viz. corona discharge, "1" stands for surface discharge and "2" stands for void discharge. Comparative analysis of all the parameters is shown in Fig.7 below.



Fig.7. Comparative plot of Precision, Recall and f1-score for all three known discharges from GNB Method

Table I shows the hyper-parameters used in GNB Method. Any algorithm that has hyper-parameters contributes significantly to the model output, therefore it is best to determine the optimal (or near-optimal) hyper-parameter combination. Hyperparameters are defined as the features of a model that can be defined by the user. It differs from parameters as during the workout, the parameters are changed internally, not before the workout, by the user.

dd	Hyperparameters	Description	Value
1	Priors	"Priorities of the classes If this option is selected, the priors are not adjusted based on the data"	NONE
2	Var ("Smoothing")	"A portion of the largest variance of all the features is added to variances to calculate stability"	1.00e-09

Table I. Table showing hyper-parameters used in GNB Method



Fig.8. Attributes disseminations and statistical breakdown of the used dataset

Fig.8. shows the Attributes disseminations and statistical break down of the used dataset used as we can see from the last column and last row figure that how we can reach to target.

•	Naive Bayes			
	[]	<pre>from sklearn.naive_bayes import GaussianNB</pre>		
	[]	gnb = GaussianNB() gnb.fit(X_train, y_train)		
		GaussianNB(priors=None, var_smoothing=1e-09)		
	[]	<pre>print("Detailed classification report:") y_true, gnb_pred = y_test, gnb.predict(X_test) print(classification_report(y_true, gnb_pred)) confusion = confusion_matrix(y_test, gnb_pred) print('Confusion Matrix:') print(confusion)</pre>		

Fig.9. Steps for execution of GNB method on google co-laboratory window

Above figure shows the programming steps for execution of the GNB method, after uploading the preprocessed data obtained from statistical method, click on these 3 steps so that the program will get executed and output can be seen on GUI (as shown in Fig.3, Fig 4 and Fig.5)

DISCUSSION AND CONCLUSION

Unidentified data	Partial discharge Source
UD 1	Surface Area
UD 2	Surface Area
UD3	Void Area

Table II. Results of GNB Method

It was seen those results of unknown data, data2 were not clearly confirming the source of discharge as void or surface using Statistical method in MATLAB software. But now, it can be finally concluded using GNB method using Python software that the data2 discharge is definitely a surface discharge. The accuracy from this method is 87.26%.

Kajol Chaudhari, Akhilesh Kumar Mishra, Priyanka Kothoke, Yogesh Chaudhari

Created a common model and confirmed the results accurately for type of PD. Use of google co-laboratory gives accurate results. The advantage of google co-laboratory in Python is to reduce the error to zero faster.

Advantage of using GNB is to increase the speed of PD type recognition and avoid a lot of power supply failures in industry. GNB can be considered as the best method for detecting type of PD since it is giving accurate results.

Finally, it can be concluded as --For detection of type of partial discharge will suggest to use GNB method.

Reference

- "Statistical Pattern Analysis of Partial Discharge Measurements for Quality in High Assessment of Insulation Systems Voltage Electrical Machinery Birsen Yazici Symporium on Diagnostin far Electric Machines", Power Electronics and Drives Atlanta, Georgia, GA USA 24-26, August 2003.
- [2] Akimasa Hirata, Syou Nakata, and Zen-Ichiro Kawasaki, "Toward Automatic Classification of Partial Discharge Sources With Neural Networks", IEEE transactions on power delivery, vol. 21, no. 1, january 2006.
- [3] J. R Hyde and I. J. Kemp, "Partial Discharge Pattern Recognition and Associated Technologies", IEEE Colloquium on Monitoring Technologies for Plant Insulation,1994.
- [4] S.H.Park, K. W.Leel, K.J.Lim. and S.H.Kang, "Classification of External and Internal PD Signals Generated in Molded Transformer by Neural Networks", Proc. of the 7th Int. Conf. on Properties and Applications of Dielectric Materials June 1-5 Nagoya P2-41, 2003.
- [5] Shan Ping', XuDake', Wang Guolil, Li Yanming, "Application of Neural Network with Genetic Algorithm to UHF PD Pattern Recognition in Transformers", Annual Report Conference on Electrical Insulation and Dielectric Phenomena, 2002.
- [6] E. Gulski and F. H. Kreuger, "Computer-aided recognition of Discharge Sources", IEEE Trans. on Electrical Insulation Vol. 27 No. 1, February, 2001.
- [7] S. Ghosh and N.K. Kishore, "Modelling Of Partial Discharge Inception And Extinction Voltages Of Sheet Samples Of Solid Insulating Materials Using an Artificial Network", Proc. Of IEE Volume: 149, Issue: 2 2002.
- [8] Gagan Deep Meena, Dr. Girish Kumar Choudhary, Manoj Gupta, "Neural Network Based Recognition Of Partial Discharge Patterns", International Journal of Advanced Engineering Research and Studies. Vol. I/ Issue II/January-March, 2012/121-126.
- [9] V. M. Catterson, B. Sheng, "Deep Neural Networks for Understanding and Diagnosing Partial Discharge Data", Institute for Energy and Environment, University of Strathclyde, Glasgow, United Kingdom.
- [10] M. A. Salama, and R. Bartnikas," Determination of Neural-Network Topology for Partial Discharge Pulse Pattern Recognition", IEEE Transactions On Neural Networks, Vol. 13, No. 2, March 2002.
- [11] Radio Location of Partial Discharge Sources: A Support Vector Regression Approach K. P. Bennett, and C. Campbell, "Support vector machines: hype or hallelujah," ACM SIGKDD Explorations Newsletter, vol. 2, no. 1, pp. 1-13, 2000.
- [12] M. Junshui, T. James and P. Simon, "Accurate On-line Support Vector Regression", Neural Computation, vol. 15, no. 11, pp. 2683-- 2703, 2003.
- [13] Shikha Agarwal, Balmukumd Jha, Tisu Kumar, Manish Kumar, Prabhat Ranjan, "Hybrid of Naive Bayes and Gaussian Naive Bayes for Classification: A Map Reduce Approach", International Journal of Innovative Technology and Exploring Engineering (IJITEE) ISSN: 2278-3075, Volume-8, Issue-6S3, April 2019.
- [14] Dana Bani-Hani, Pruthak Patel & Tasneem Alshaikh, " An Optimized Recursive General Regression Neural Network Oracle for the Prediction and Diagnosis of Diabetes", Global Journal of Computer

Science and Technology: D Neural & Artificial Intelligence Volume 19 Issue 2 Version 1.0 Year 2019.

- [15] Namrata Bhosale, Priyanka Kothoke Amol Deshpande, Dr. Alice Cheeran, "Analysis of Partial Discharge using Phase-Resolved(φ-q) and (φ-n) Statistical Techniques", International Journal of Engineering Research and Technology, Vol. 2 (05), 2013,ISSN2278-0181.
- [16] Priyanka Kothoke, Namrata Bhosale, Amol Deshpande, Dr. Alice Cheeran, "Analysis of Partial Discharge using Phase-Resolved (n-q) Statistical Techniques", International Journal of Engineering Research and Applications.
- [17] Yogesh R. Chaudhari, Namrata R. Bhosale, Priyanka M. Kothoke, "Composite Analysis of Phase Resolved PD Patterns using Statistical Techniques", International Journal of Modern Engineering Research (IJMER) Vol. 3, Issue. 4, pp-1947-1957, 2013.
- [18]. Priyanka Kothoke, Dr. Anupama Deshpande, Yogesh Chaudhari, "Investigation and Determination of PD source utilizing SVR and RF", International Conference on Inventive Computation Technologies (ICICT-2020), inclusion into IEEE Xplore and Scopus.
- [19] Priyanka Kothoke, Dr. Anupama Deshpande, Yogesh Chaudhari, "Examination and Determination of Partial Discharge Source utilizing SOM and BPM Techniques of ANN", International Journal of Advanced Science and Technology, Vol. 29, No. 8s, (2020), pp. 3299-3306.
- [20] Priyanka Kothoke, Dr. Anupama Deshpande, Yogesh Chaudhari, "Analysis and Determination of Partial Discharge Type using Statistical Techniques and Back Propagation Method of Artificial Neural Network for Phase Resolved Data;", International Journal of Engineering Research and Technology(IJERT), Vol. 08, Issue 08, August 2019.